

# CITY OF WILLARD CSO PUBLIC NOTICIATION

## ***SUPPLEMENTAL NOTIFICATION***

To all concerned public and other agencies:

A combined sewer overflow (CSO) has ended from the City of Willard CSO holding lagoon. Pertinent information is as follows:

Date and Time CSO began:	04/01/2026 2:45 pm
Date and Time CSO ended:	04/02/2026 6:00 am
TOTAL DURATION:	15 hours & 15 minutes
Location of discharge:	City of Willard Combined Sewer Lagoon 611 Keefer Street <u>Willard, Ohio 44890</u>
Discharge stream:	Jacob Creek
Treatment provided:	screening of combined sewage
Status at time of this notification:	not active the CSO event has ended
Areas affected:	West Branch of Huron River Holiday Lakes Monroeville
Rainfall prior to beginning:	2.59 inches
Total Rainfall this CSO event:	2.74 inches

TOTAL CSO VOLUME 7.78 million gallons

For more information contact: Scott Pifher (419) 933-7515  
[spifher@willardohio.gov](mailto:spifher@willardohio.gov)  
Matt Brooks (419)-933-7515  
[mbrooks@willardohio.gov](mailto:mbrooks@willardohio.gov)